



Minnesota
Pollution
Control
Agency

Water Quality

Wastewater
Technical
Review and
Guidance

BIOLOGICAL TREATMENT CHECKLIST – SUSPENDED GROWTH – ACTIVATED SLUDGE, OXIDATION DITCHES

Water/Wastewater/#5.10, April, 2001

FACILITY NAME

DATE

CONSULTING ENGINEER

SITE INSPECTION (DATE & INSPECTOR)

PLANNING OR DESIGN PHASE

INTRODUCTION

The activated sludge process is an aerobic biological process, which uses the metabolic reactions of microorganisms to attain an acceptable effluent quality by removing substances exerting an oxygen demand. There are many modifications of activated sludge that can be used to meet specific treatment requirements. These modifications consist of and are defined as follows:

Conventional Activated Sludge - The conventional activated sludge process consists of an aeration tank, a secondary clarifier and a sludge recycle line. Both influent sewage and recycled sludge enter the tank at the head end, move through the tank in plug flow and are aerated for a period of time.

Step Feed Activated Sludge - The Step feed process (sometimes called Step Aeration) is a modification of the activated sludge process in which sewage is introduced at two or more points in the aeration tank while return sludge is introduced only at the head end of the aeration tank. In this modification, the oxygen demand is more uniformly spread over the length of the aeration tank.

Tapered Aeration Activated Sludge - The tapered aeration activated sludge process is a modification of the conventional activated sludge process. Tapered aeration affects only the arrangement of the aeration devices in the aeration tank. In tapered aeration the diffusers or aeration devices are spaced closer together at the head end of the tank to match the oxygen demand.

Contents:

General.....	3
Pretreatment.....	4
Aeration	4
Aeration Equipment -	
Diffused Air	6
Aeration Equipment –	
Mechanical	9
Return Sludge.....	10
Measuring Devices	11
Oxidation Ditches	11
Protective and Service	
Facilities	13

wq-wwtp5-10

Minnesota Pollution Control Agency, 520 Lafayette Road North, St. Paul, Minnesota 55155-4194

(651) 296-6300, toll-free (800) 657-3864, TTY (651) 282-5332 or (800) 657-3864

This material can be made available in alternative formats for people with disabilities.



Printed on recycled paper containing at least 20 percent fibers from paper recycled by consumers.



Complete Mix Activated Sludge - The complete mix activated sludge process is characterized by distributing the influent sewage, return sludge and air equally throughout the aeration tank to form a nearly homogeneous mixture in the tank. The organic load and thus oxygen demand is uniform from one end of the tank to the other.

Contact Stabilization Activated Sludge - The contact stabilization activated sludge process utilizes two aeration compartments to divide the two phases of BOD removal. The first phase, adsorption, takes place in the first aeration tank (contact tank). Mixed liquor from the contact tank then flows to the clarifier. Return sludge flows to the second aeration tank (reaeration tank) where the second phase, absorption, occurs. The reaeration tank provides detention time before flowing into the contact tank.

Extended Aeration Activated Sludge - The extended aeration activated sludge process operates in the indigenous respiration phase of the growth curve, which necessitates a relatively low organic loading (low F/M) and long aeration time.

Oxidation Ditch Activated Sludge - The oxidation ditch activated sludge process is an extended aeration process utilizing a ring-shaped channel and aeration than provides continuous flow around the channel.

Pure Oxygen Activated Sludge - Pure oxygen activated sludge is characterized by the use of high purity oxygen instead of air for aeration. 30

I. DESCRIPTION OF FACILITY – Provide a short description of the proposed facility:

Hydraulic and Organic Loading / Design Flow

Average Wet Weather (AWW)	_____	gals/day
Peak Hourly Wet Weather (PHWW)	_____	gals/day
Peak Instantaneous Wet Weather (PIWW)	_____	gals/day
Organic Loading, CBOD ₅	_____	lbs/day
Explain Primary modification of activated sludge	_____	
Type of activated sludge process chosen	_____	
Type of Aeration	_____	

Tank Dimensions and Volume	_____	
Detention time in aeration basin	_____	hrs
Aeration tank organic loading (CBOD/day/1000ft ³)	_____	
Design F/M ratio	_____	
Design MLSS	_____	
Process Preceded by (specify process)	_____	
Process Followed by (specify process)	_____	



Final effluent limitation

mg/L CBOD5

mg/L TSS

mg/L Ammonia (min.
concentration)

mg/L Phosphorus

GENERAL

Calculations and/or documentation shall be submitted to justify the basis of design for the following:

- a. Process efficiency.
- b. Aeration tanks.
- c. Aeration equipment (including oxygen and mixing requirements)
- d. Secondary clarifiers
- e. Return sludge equipment
- f. Waste sludge equipment
- g. Sludge handling facilities

Wastewater must be amenable to biological treatment. Check for industrial discharges that may cause a nutrient imbalance, variable pH or temperature, or toxic or slug discharge. Certain dairy wastes, paper wastes, potato wastes particularly should be examined for nutrient deficiencies.

City has sufficient equipment, trained perator, financial resources, etc. to properly operate and mangle this system:

Efficient use of energy is provided?

Particular attention should be given to initial operation when oxygen demands may be significantly less than the design oxygen demand. The design should always maintain the minimum mixing levels; mixing may control power requirements at low oxygen demands. Energy conservation measures should be considered in design of aeration systems. For diffused aeration systems, the following should be considered:

- a. Use of smaller compressors and more units.
- b. Variable-speed drives on positive-displacement compressors.
- c. Intake throttling on centrifugal compressors.
- d. Use of high-efficiency diffusers.



For mechanical aeration systems, the following should be considered:

- a. Use of smaller aerators.
- b. Variable aeration tank weirs.
- c. Multiple speed motors.
- d. Use of timers.

Duplication of critical units (pumps, aerators, motors) as well as standby units (tanks etc.) have been provided. See “Reliability Guidelines.”

Standby or auxiliary power is provided for aeration and pumping equipment.

TYPE

Flexibility allows for at least three modes of operation (two for extended aeration). Flexibility refers to providing several modification, series and parallel operation, numerous return and waste sludge flow options, etc. If feasible, aeration tank systems, except extended aeration, should be designed to accommodate at least three (3) modes of operation (such as plug flow, complete mix, contact-stabilization, step feed etc.). Two (2) modes of operation for extended aeration systems larger than 1893 m³/day (0.5 MGD) should be considered. Design of aeration systems should provide adequate flexibility to vary the oxygen transfer capability and power consumption in relation to oxygen demands.

MODES

Protection of aeration tanks, clarifiers and equipment from freezing. Winter protection for the aeration tanks may consist of windwalls, earthen bank insulation, and extra freeboard, etc. Other equipment such as blowers, pumps, etc. should also be protected. Secondary clarifiers and aerobic digesters should be covered under certain conditions.

TYPE

PRETREATMENT

Grit removal, scum and comminution or screening

AERATION

Number of Units – The requirements for dual aeration tanks shall be as listed in MPCA’s Reliability for Mechanical Wastewater Treatment Plants Guidelines.

- a. Additional aeration tanks designed specifically for nitrogen removal shall not be used for satisfying the requirement of dual aeration tanks for secondary treatment activated sludge.



- b. Plants with initial flows of less than one-half design should have at least two (2) aeration basins. All flow splitting devices shall have vertical inlet into the splitter and split by overflowing horizontal surfaces at the same elevation.
- c. When two (2) or more tanks are installed, both series and parallel flow schemes should be available. In addition each train of aeration tank(s) and clarifier(s) shall have its own separate return and waste sludge pumping facilities, as well as intergroup return and wasting sludge capabilities.

ARRANGEMENT OF AERATION TANKS

- a. **Dimensions** – Deep aeration tanks utilizing surface aeration should be avoided without assurance of adequate mixing. Spiral flow refers to the circular flow pattern that results what the diffusers are located along one wall of the aeration tank. Fillets should be provided around the bottom of aeration tanks where the wall and bottom meet to eliminate dead spots.

Do any unusual factors exist that will affect design such as excessive diurnal load (>4:1, <2:1) variations, stricter degree of treatment than 25 mg/l BOD, 30 mg/l TSS, temperatures, pH, etc. Wastes with high concentrations of BOD diurnal load ratios or peak hourly BOD5 to average BOD5 of greater than 4:1. may be handled best by complete mix activated sludge because BOD is dispersed completely through tank and makes maximum use of dilution. Contact Stabilization may not be practical for wastewater with a high soluble BOD such as dairy waste. Lab tests should be performed on mixtures of industrial and domestic wastes. Conventional activated sludge may be designed for slightly higher organic loadings if the system also has the capability to operate in a mode that can handle higher loadings. For step feed plants, influent hydraulic design should permit all flow to enter any single pass. The flow to each pass must be controllable.

CRITERIA

Liquid depth in aeration tank, should not be less than 10 or more than 30 feet. Horizontally mixed aeration tanks shall have a depth of not less than 5.5 (as an exception).

FT

Shape of tank and installation of aeration equipment shall avoid short-circuiting.



Access must be available to allow for observing aeration tank contents, mixing pattern, sampling, etc., in aeration tank and settling, scum collection, level weirs, etc., in clarifier.

Each compartment has load-bearing walls for individual compartment dewatering. Slope bottom to assure complete drainage. Aeration tank drainage should be discharged upstream of the activated sludge process.

Piping for bypassing and dewatering each individual compartment is provided?

Pressure relief valves in each compartment provided? Tanks with freeboard greater than 18' shall provide rails, steps or other means of egress from each aeration tank. Additional freeboard or windbreak may be necessary to protect against freezing or windblown spray. Walkways should be located and/or designed to preclude spray and foam from freezing on their surfaces. Locating walkways away from or sufficiently elevated, above water levels and using grated walkways are examples of methods used to prevent ice build up.

Aeration Tank freeboard, minimum 18 inches.

IN

If a mechanical surface aerator is used, the freeboard should not be less than 3 feet to protect against windblown spray freezing on walkways, etc.

AERATION EQUIPMENT-DIFFUSED AIR

In diffused air systems, a minimum air flow volume of 20-30 scfm/1000 ft³ than volume is required for adequate mixing velocities and to avoid depositing of solids. For a grid aeration system, mixing rates of 10 to 15 ft³/min/1000ft³ is sufficient.

A bypass to the atmosphere should be installed avoid surging. The bypass should be arranged to be open at starting and at all times when the airflow is less than that at the surge point.

Aluminum pipe should be avoided due to corrosion problems.



Centrifugal blowers should and rotary positive displacement blowers must be provided with both inlet and discharge silencers to reduce the high pitched whine that is transmitted to the piping.

Surging will result If the blower is throttled on the discharge side or by adjustment of the air valves at the aeration tanks to capacity equal to or less than that at the peak of the head-capacity curve.

Total aeration tank volume shall be divided between two or more units, capable of independent operation, for reliability.

Both parallel and series operation are available when two or more aeration tanks exist.

Inlets and outlets of aeration tank shall be equipped with valves, gates, plates, weirs or other devices to control flow to any unit and to maintain constant liquid level.

The effluent weir for a horizontally mixed aeration tank system must be easily adjustable by mechanical means and shall be sized based on the design peak instantaneous flow plus the maximum return sludge flow.

Design peak instantaneous flow can be carried with any single aeration tank unit out of service.

All channels and pipes designed to maintain self-cleansing velocities. Min. 2' / Sec

FT/SEC

Channels not being used during alternate flow patterns can be drained

Minimum dissolved oxygen concentration that can be maintained by aeration equipment. Should be at least 2 mg/l D.O.

Mg/l

Design oxygen requirements in lbs. O₂/lb. Peak BOD₅ applied to aeration tanks (Minimum 1.1 lbs. O₂/lb. BOD₅, except extended aeration the value shall be 1.5).

LBS O₂
DAY

For **nitrification** oxygen demand of recycle flow must be added to determine O₂ requirement

LBS O₂

Total oxygen requirement, BOD recycle plus **nitrification** in lbs. O₂/lbs. BOD.

LBS O₂
DAY



Alpha and Beta factor (50% of clean water efficiency where 90 % + waste is domestic sewage, higher industrial percentages should use less than 50 % of clean water efficiencies and calculations need be submitted to justify)

ALPHA

BETA

Certified aeration device transfer efficiency.

Air requirements for diffused air systems, ft³/lb BOD peak aeration tank loading. (500 ft³/lb BOD except extended aeration which shall be 2050 ft³/lb BOD.)

CUBIC FT/LB BOD

Air requirements for additional air for channels, pumps, digesters, etc.

CUBIC FEET/MIN

Total air requirements, ft³/Min.

CUBIC FEET/MIN

High air intake temperature for blower (should be designed for 115°F (45°C)).

F°

Low air intake temperature for motor drive (should be designed for -20°F (-29°C))

F°

Blowers in multiple units and can meet maximum air demand with single largest unit out of service

Air rate shall be variable or adjustable. For energy conservation

Adequate workspace shall be provided around each blower and other equipment (2' minimum). For easy maintenance access.

FT

Diffuser systems designed for diurnal peak oxygen demand or 200% of design average oxygen demand, whichever is greater.

PEAK OR 200%

Total head loss from blower outlet of silencer to diffuser inlet (should not exceed 0.5 psi at average operating conditions.

psi

Spacing of diffusers should be in accordance with oxygen requirements through length of tank and designed to facilitate adjustment of aeration throughout tank.

Diffusers are removable without dewatering aeration tank.

Hoist provided to raise diffusers.



Individual diffusers are equipped with control valves with indicator markings for throttling, or for complete shutoff.

Air filters with easy access provided for blowers.

Soundproofing provided between blower room and other work areas.

Airflow rate meters provided for each aeration compartment in addition to a total air flow rate meter.

AERATION EQUIPMENT – MECHANICAL

Design Requirements – Provide mixing with use of a draft tube. Mixing requirements vary from .75 to 1.5 hp/1000ft³ tank volume for complete mixing. Adjustable aeration tank outlet weirs are desirable with mechanical aerators for varying submergence of the aerator. Aeration devices in small plants may have time minute increments.

Reliability – An additional motor (and bearings for brush aerator systems) shall be provided for single mechanical aerator systems.

Oxygen requirements, lbs. 92/Hr.

DAY

Certified testing of mechanical aerator and drive unit shall verify lbs. O₂/Hr.

In the absence of specific design information, the oxygen requirements shall be calculated using a transfer rate not to exceed 2 lbs. Of oxygen per horsepower per hour in clean water under standard test conditions.

Minimum D.O. maintained by mechanical aeration system (2 mg/l).

mg/l

Mechanical aeration system can maintain all biological solids in suspension (for a horizontally mixed aeration tank system an average velocity of 1 ft. per second must be maintained).

Can mechanical aeration system meet maximum oxygen demand and maintain process performance with largest unit out of service.

Provide for varying the amount of oxygen transferred (adjustable mechanism, adjustable aeration tank outlet weirs, time clocks for smaller facilities, etc.)



Provide that motors, gear housing, bearings, grease fittings, etc., and be easily accessible and protected from inundation and spray as necessary for proper functioning of the unit. Aerators shall be removable without dewatering tanks on shutting off air supply to other tanks.

Protection from freezing and excessive ice build up.

RETURN SLUDGE EQUIPMENT

Return Sludge Rate – Timers should be considered only as a last resort. Timers should allow for operation in five (5) minute increments. Airlift pumps used for return sludge and waste sludge shall have air flow regulators with gauged handles for control of return sludge and waste sludge rates.

Return Sludge Pumps - Air lifts commonly plug up at top, so access must be provided at top of airlift to remove accumulated debris.

Return Sludge Piping - Observation and sampling of waste sludge, as well as return sludge, should be provided from a safe vantage point. Return sludge should be added to the influent wastewater prior to entering the aeration tank or added to the aeration tank in a manner and location that assures adequate mixing with the influent waste.

Minimum return sludge rate as percentage of design average flow (DAF).

%

Maximum return sludge rate (%)

%

Method of varying rate of sludge return (variable speed motors, drives or timers; timers for small facilities and as a last resort only) obtained with largest return pump.

TYPE

Can maximum return sludge capacity be obtained with largest return pump blower out of service?

Size of suction and discharge openings on return sludge pumps (three-inch minimum).

IN

Do airlifts allow rapid and easy cleaning?

Diameter of airlift (minimum three inches).

IN

Diameter of return sludge discharge (four-inch minimum).

IN

Design velocity of return sludge piping at normal return sludge rates (minimum two feet per second).

FPS

Devices provided for observing, sampling, measuring and controlling return sludge flow from each settling tank

OBS.
SAMP.
MEAS.
CONT.



Type of waste sludge handling.	_____
Type of waste sludge control (manual, timer, % of return sludge, etc.)	_____
Maximum capacity of waste sludge control facilities as percentage of average rate of sewage flow (not less than 25%).	_____ %
Minimum capacity of waste sludge control facilities as percentage of average rate of sewage flow (0.5 % or 10 gal/min, whichever is larger).	_____ %
Devices provided for observing, sampling, controlling and measuring waste activated sludge flow (list type separately).	OBS. SAMP. MEAS. CONT _____
Where is waste sludge discharge?	_____

MEASURING DEVICES

Measurement devices should be located to measure flows to each tank unit. This means if flow splitting is utilized, measurement should be located downstream of the flow splitting device to measure flows after splitting. When a totalizer and recorder are available to measure flows prior to flow splitting, a weir may be sufficient to satisfy flow measurement after splitting.

For facilities over 1 MGD, can measuring devices for return and waste sludge also total and record?

OXIDATION DITCHES

In addition to the above criteria concerning activated sludge facilities, oxidation ditches should conform to the following recommendation.

Sidewalls and bottoms of oxidation ditch channels are tied together with reinforcing bar or are poured as on slab to eliminate frost heave?

There must be something holding the walls and bottom together to prevent frost heaving causing separation. The weight sufficient to prevent this separation.

Type of backfill for oxidation ditch channel (should be sand with drainage).

Type of cover ground between channels.

The areas between the channels should be covered with an impermeable material to prevent rainwater from entering the ground between the channels.

TYPE



Location of influent and return sludge lines with respect to rotor (lines should be upstream for best mixing).

Location of ditch discharge to final clarifier with respect to rotor (should be upstream of rotor and far enough upstream of influent and return sludge to prevent short-circuiting). The discharge weir shall be designed to withdraw mixed liquor from below the channel water surface such as through the use of a baffle in front of the weir. A baffle in front of the ditch overflow weir will prevent decanting clear liquid from the ditch. A floating draw off weir should be encouraged.

Water level control in aeration channel (should be adjustable weir).

Weir length of channel discharge (use maximum raw flow plus maximum recirculated flow to determine weir length to prevent excessive rotor immersions).

FT

Type of access to rotor for maintenance (should be at least walkways located upstream of rotor and located to prevent spray from rotor on walkway).

Horizontal baffles should be located within 15 feet downstream of brush aeration in channels with water depth over six feet. This provides proper mixing of the entire depth of the basin. Channels using jet aeration may be deeper and should have a water depth as recommended by the manufacturer.

In a single channel, rotor drive assembly should be on outboard side.

Drive and gear assembly elevated out of water for safe and easy access.

Equipment requiring normal maintenance should be housed and /or heated.



PROTECTIVE AND SERVICE FACILITIES

Ladders, hoists and walkways provided for easy access to equipment, pipes and valves for normal operation, routine maintenance or repair.

Tanks with freeboard greater than 18" shall provide rails, steps or other means of egress from each aeration tank. Additional freeboard or windbreak may be necessary to protect against freezing or windblown spray. Walkways should be located and /or designed to preclude spray and foam from freezing on their surfaces. Locating walkways away from or sufficiently elevated, above water levels and sing grated walkways are examples of methods used to prevent ice build up.

Hoisting equipment available for blowers, pumps and other heavy equipment

Adequate remote and local controls provided for mechanical equipment, especially waste sludge pump, return sludge control, sludge loadout, etc.

Chlorination flexibility provided for chlorination of return sludge.

Laboratory equipment to be provided, should be MLSS, settlemeter, settleability and dissolved oxygen. Consider minimum "Process Control" Tests.

Railings or other protective walls shall be placed around all aeration tanks.

List safety equipment to be provided near aeration tanks and clarifiers. Should include safety vests, lifelines, and rings and safety poles.

Sufficient lighting should be provided to permit safe working conditions near aeration tanks and clarifiers at night.