

February 23, 2026

Mr. Mark Noga, President  
Knight Treatment Systems, Inc.  
281 County Route 51A  
Oswego, NY 12126

**RE: Product Registration Renewal – Notice of Conditional Product Registration for Proprietary Treatment Product Listing**

Description: Sewage Treatment System, Attached and Suspended Growth-Microbial Inoculator Generator (MIG)  
Manufacturer: Knight Treatment Systems, Inc.  
Product Name: White Knight Microbial Inoculator Generator™ (White Knight MIG™)  
Model Number: White Knight MIG™ Models WK 40, WK 78, WK 150, and WK 200  
Product Listing: Category B (high strength sewage)

Dear Mr. Noga:

Thank you for your product renewal application dated January 12, 2026 for the White Knight MIG™, including Models WK 40, WK 78, WK 150, and WK 200.

In accordance with Minn. R. chs. 7080 through 7083, the Minnesota Pollution Control Agency (MPCA) has reviewed Knight Treatment Systems, Inc. submitted materials requesting registration for Category B (high strength sewage) treatment product listing of the White Knight MIG™ in this application. Based on the submitted documentation, the MPCA finds that the White Knight MIG™ is eligible for Interim Conditional Product Registration as meeting the following treatment level:

- **Treatment Level C** (cBOD<sub>5</sub> of 125 mg/L, TSS of 60 mg/L and Oil & Grease of 25 mg/L)

The White Knight MIG™ is conditionally registered with a design rated capacity of 4, 8, 12, and 15 pounds of BOD<sub>5</sub> per day, as shown in Table 1, for high strength wastewater applications only.

Subject to this determination, the White Knight MIG™ (Models WK 40, WK 78, WK 150, and WK 20) will be placed on the List of Registered Subsurface Sewage Treatment System (SSTS) Products for High Strength Wastewater. The product information listed in this Notice of Interim Conditional Product Registration for Proprietary Treatment Product Listing will be maintained on the MPCA website and may not be altered or misrepresented by the manufacturer or any other person without permission by the MPCA.

**Table 1. The White Knight MIG™**

Product Name Model	Treatment Process	Maximum Design Flow (gallons per day)	BOD5 Loading (lbs/day)	Registered Treatment Level	Product Information
White Knight MIG™ Model WK 40 1 Tower per Unit	Attached and Suspended Growth	1000	4	C	<ul style="list-style-type: none"> <li>● Notice of Interim Conditional Product Listing <ul style="list-style-type: none"> <li>○ MPCA Letter</li> <li>○ Conditions of Registration</li> <li>○ Expiration Date</li> </ul> </li> </ul>
White Knight MIG™ Model WK 78 2 Towers per Unit	Attached and Suspended Growth	2000	8	C	<ul style="list-style-type: none"> <li>● The White Knight MIG™ Manual <ul style="list-style-type: none"> <li>○ Submitted Drawings</li> <li>○ Sizing Guideline Calculator</li> <li>○ Design Instructions</li> <li>○ Site Evaluation Form</li> <li>○ Installation Instructions</li> <li>○ Installation Check List</li> <li>○ Operation &amp; Service Manual</li> <li>○ Service Visit Record</li> </ul> </li> </ul>
White Knight MIG™ Model WK 150 3 Towers per Unit	Attached and Suspended Growth	3000	12	C	
White Knight MIG™ Model WK 200 4 Towers per Unit	Attached and Suspended Growth	4000	15	C	<ul style="list-style-type: none"> <li>● Management Plan</li> <li>● Operating Permit Template</li> </ul>

\* The White Knight MIG™ is registered for residential and commercial high strength wastewater applications and high strength wastewater remediation with design flows to 10,000 gallons per day.

The registration of the treatment products in Minnesota is contingent upon compliance with the following conditions:

1. Products must be used in compliance with the MPCA rules and the plans and design information provided during the period of initial product application. The White Knight MIG™ must not be used on a system failing to protect groundwater as defined in Minn. R. 7080.1500, subp. 4(B).
2. The manufacturer shall have readily accessible information, specific to a product’s registered use in Minnesota, for designers, regulators, installers, system owners, service providers and other

interested parties for the following items: a) product manual; b) design instructions; c) installation instructions; d) information regarding operation and maintenance; e) homeowner instructions; and

f) list of representatives and manufacturer-certified service providers, if any, as required by Minn. R. 7083.4040 (H).

3. The design parameters for pounds of BOD<sub>5</sub> applied to the White Knight MIG™, including Models WK 40, WK 78, WK 150, and WK 200, are as follows for commercial and residential high strength applications and high strength wastewater remediation:
  - 1) 4 pounds BOD<sub>5</sub> per day for the White Knight MIG™ Model WK 40
  - 2) 8 pounds BOD<sub>5</sub> per day for the White Knight MIG™ Model WK 78
  - 3) 12 pounds BOD<sub>5</sub> per day for the White Knight MIG™ Model WK 150
  - 4) 15 pounds BOD<sub>5</sub> per day for the White Knight MIG™ Model WK 200
4. The manufacturer's designated representative is required to review all designs provided by Intermediate/Advanced Designers (i.e.: evaluation worksheets for high strength wastewater) for treatment systems proposed to use the White Knight MIG™. Designers need to work directly with the manufacturer to ensure the wastewater is properly characterized and that White Knight MIG™ high strength wastewater treatment products, and other related components used in treatment train (i.e.: grease interceptors, septic tanks, surge tanks and clarifier tanks), are properly sized and compatible to meet designed performance requirements.
5. The manufacturer's designated representative will issue a review letter to the Designer documenting: 1) details of the manufacturer's review, and 2) agreement that the product is an appropriate fit for the planned system at the facility. The review letter will be signed by the manufacturer's designated representative.
6. Systems installed using the White Knight MIG™ require a trash tank prior to the septic tank. Trash tank capacity shall meet the minimum size requirements as specified by the manufacturer and other applicable tank requirements from Minn. R. 7080.1910 to 7080.2030.
7. Treatment tanks used in conjunction with the White Knight MIG™ must be appropriately sized in accordance with Minn. R. 7080.1930 septic tank sizing, and must be registered for use by the MPCA. Trash tank volume may be added to help satisfy the minimum sizing requirements.
8. Each system must be delivered with an installation manual and owner's manual for the White Knight MIG™. Each component must be installed in accordance with the manufacturer's installation manual.
9. Knight Treatment Systems, Inc., or its designated representative, along with the Intermediate/Advanced Designer and Installer, are responsible to ensure that proper flow splitting devices are used to split flows between two or more units in parallel. Flow splitting devices must meet the following criteria: a) designed specifically and reliably to split wastewater flows; b) accessible for on-going operation and maintenance; c) monitored to determine flow rates; d) adjustable after construction should settlement occur; and e) have infinite or continuous adjustment features.

10. To protect for potential system malfunction, all systems shall be designed and operated with a suitable alarm device(s) that monitors the White Knight MIG™ and its various components.
11. The treatment products contained in this notice of product registration are considered a Minnesota-registered product for Type IV High Strength Waste systems.
12. The White Knight MIG™ (Models WK 40, WK 78, WK 150, and WK 200) is registered to be used in systems to achieve Treatment Level C. The effluent loading rates to the soil, method of distribution, and vertical separation requirements shall meet the minimum requirements contained in Minn. R. 7080.2150 for flows less than 5000 gpd. For flows greater than 5000 gpd, final treatment and dispersal must also meet Minn. R. 7081.0270. Systems installed using the White Knight MIG™ must be installed using pressure distribution. Pump tanks used must meet minimum requirements of Minn. R. 7080.2100, subp. 2. An alarm device is required on all pump tanks in the event the pump malfunctions.
13. All systems shall be designed and operated with a manufacturer approved effluent screen, as specified in the Design Manual. All systems shall be designed and operated with a suitable alarm device(s) should the effluent screen malfunction.
14. Systems may only be designated as Type IV systems when designed and installed per the drawings submitted as part of the Application for Registration, dated September 30, 2021, and subsequent documents submitted prior to this registration.
15. As a Type IV system, the system must be constructed and operated under the required local permits.
16. The manufacturer is responsible to provide a listing of other known limitations, to be made available on the company's website or other means. The level of maintenance required for the White Knight MIG™ shall be as specified in the Operation and Service Manual.
17. Training shall be provided to MPCA-licensed Subsurface Sewage Treatment System practitioners before designing, installing, or providing service to White Knight MIG™ treatment systems registered for use in Minnesota.
18. At the time of product renewal during the year 2028 and according to the "Proprietary treatment technology registration guidance – high strength waste". Manufacturers must submit data in accordance with the HSW verification protocol for each system installed under this protocol. If product manufacturers fail to submit data as outlined in the HSW verification protocol for each system installed their registration will be discontinued until submission of the required data. Renewal requirements as stated in this guidance will be communicated to manufacturers in a letter from the MPCA prior to their expiration deadline. Product manufacturers must submit renewal materials as specified in their renewal letters.
19. During the period of product registration and as part of the renewal process, systems using registered treatment products are subject to an audit by the MPCA.

## HSW verification protocol

An established set of requirements to verify product performance is necessary to set a consistent standard among all registered HSW treatment technologies. This protocol (table 1) takes one full year to complete and as mentioned previously must be completed on every system installed after registration, in perpetuity, until such time that the TAP modifies, expands, alters, or cancels the protocol requirements.

**Table 1. HSW verification protocol**

Item	Description
Sample identification	Third-party sample reports must clearly indicate from which system/facility the samples were derived. Reports must also contain sample dates and times, sample location information, name of sampler, chain of custody information, sample collection method, and sample transportation information (time/container/temperature).
Sampling intervals	Four (4) sampling events (for both influent and effluent analysis as described below) must be taken quarterly each calendar year. The TAP will consider alternate intervals on seasonal use facilities to ensure required sampling events align with peak usage. Example: Q1: Jan – Mar, Q2: Apr – Jun, Q3: Jul – Sep, and Q4: Oct – Dec.
Influent sampling	Influent BOD <sub>5</sub> , TSS, and O&G composite/grab samples must be taken at the first location of sewage collection within the system and be representative of the waste being discharged from the facility. Each of these three constituents must be sampled at each sampling event per facility.
Influent waste characterization	For each set of influent data provided, the waste must be characterized as HSW in accordance with Minn. R. 7080.1550, subp. 2 B (1). Raw sewage must exceed 300 mg/L BOD <sub>5</sub> , 200 mg/L TSS, and/or 50 mg/L O&G in order to be considered high strength waste.
Effluent sampling	Effluent cBOD <sub>5</sub> (or BOD <sub>5</sub> ), TSS, and O&G composite/grab samples must be taken after the treatment device and before discharge to the soil dispersal area. Each of these constituents must be sampled for each sampling event per facility.
Effluent waste results	In all cases, the effluent waste concentrations must meet, at a minimum, the outlined parameters for Treatment Level C: BOD <sub>5</sub> of 170mg/L (or cBOD <sub>5</sub> of 125mg/L), TSS of 60mg/L, and O&G of 25mg/L.
Flow measurements	Average daily flow for thirty (30) days prior to each sampling event must be provided.
Third-party testing	All sampling results must be submitted on original reports from third-party entities (e.g., certified laboratories).
O&M summary	Create an O&M summary specifying the maintenance performed throughout the test period, such as pumping events or adjustments made, and include a list of tasks necessary for the product to adequately perform within the specified parameters in all configurations. Tasks should be given a specific frequency for when each shall occur (e.g., every 6 months).
Mandatory reporting	For all systems/facilities requiring performance verification under this protocol, please submit the following: <ol style="list-style-type: none"> <li>1. SSTS HSW Protocol Data Entry Form – for each system</li> <li>2. Original sampling results from third-party entities (e.g. certified laboratories)</li> </ol> Combine the summary reports for each system/facility into one PDF document and submit to the agency.

Mr. Mark Noga  
Page 6  
February 23, 2026

## Full registration

A product will be granted full product registration once the manufacturer completes the Proprietary Treatment Product Application for Registration, undergoes formal review, and is verified through nationally recognized testing protocols in accordance with Minn. R. 7083.4010. Renewal for full registrations will be every three (3) years.

## Final review and determination

The TAP will provide review of the summary reports submitted, and make recommendations to the agency for conditional or full product registration. The TAP has full discretion in their recommendations based on the intricacies surrounding each product's situation and registration at the time of review. Based on the recommendation from the TAP, the agency will make a final determination and develop a product registration letter reflecting their registration parameters and requirements.

**Please be advised that this registration expires December 31, 2028.** Manufacturers desiring to continue product registration beyond this date must obtain MPCA renewal according to the requirements in Minn. R. ch. 7083.4040 (E). If the product has changed or is retested according to the protocol required for registration, renewal shall be based on the most recent test results. If the MPCA finds the product has changed in any way that may affect performance, it may not be renewed and must meet the requirements for initial registration.

The MPCA is in no way endorsing these products or any advertising, and is not responsible for any situation which may result from its use or misuse. The MPCA is not liable for any product failure and these statements are not intended and cannot be relied upon to establish any substantive or procedural rights with the state of Minnesota or the MPCA, either express or implied, that can be enforced in litigation or any administrative proceeding.

If you have any questions, please contact Wendy Chirpich at 507-344-5248 or by email at [wendy.chirpich@state.mn.us](mailto:wendy.chirpich@state.mn.us).

Sincerely,

*Wendy Chirpich*

*This document has been electronically signed.*

Wendy Chirpich  
Environmental Specialist  
Municipal Division

cc: File