

Certificate of Compliance for new or replacement construction

Kingsford County

Site information

Property owner:	Steven Oscarson
Site address:	1234 Septic Lane, Rochester, MN
Property ID:	01.500.82456
Date of inspection:	6/8/2026

System components

System type and size:	Type 1, Class 1, 4--bedroom home
Septic tank(s):	Steve's 2250 S
Pump tank(s):	Steve's 600 P
Other tank(s):	NA
Soil treatment area:	Mound w/ 10*50 rockbed

Other criteria

Field check of soil conditions:	below the plastic limit 6/8/2026				
SWF:	Yes	No	Class V injection well:	Yes	No
	☐	☒		☐	☒


Vertical separation distance

Bottom of distribution medium:	102									
Periodically saturated soil/bedrock:	99									
Vertical separation:	3									
Required attachments:	Management plan	☒	Optional attachments:		☐				☐	

Comments:

"This certifies that the Subsurface Sewage Treatment System installed at the above property was inspected during installation and found to be in compliance with the local ordinance and Minnesota Rules Ch. 7080-7081. The Certificate of Compliance is valid for 5 years from the date of issuance unless the local unit of government finds evidence of noncompliance."

Inspector's name:	Corey Hillman	C-1234567
Inspector's signature:	Corey Hillman	L-7654321



Requirements

- ☒ Dwelling/other establishment
- ☒ Building sewer
- ☒ Sewage tanks
- ☒ Soil treatment area
- ☒ Well(s)