



Minnesota
Pollution
Control
Agency

CENTRIFUGES SOLID BOWL- REVIEW CHECKLIST

Water Quality

Wastewater
Technical
Review and
Guidance

Water/Wastewater/#5.13, May 2001

<hr/>	
FACILITY NAME	DATE
<hr/>	
CONSULTING ENGINEER	SITE INSPECTION (DATE & INSPECTOR)
<hr/>	
PLANNING OR DESIGN PHASE	
Feed Concentration (%)	_____
Solids Capture (%) <i>(70-95 % - depending on type of sludge & if conditioned by chemicals)</i>	_____
Cake Solids (%)	_____
Feed Rate (gpm)	_____
Sludge Conditioning Facilities?	_____
Conditioning Chemicals?	_____
Where is centrate returned to plant?	_____
Projected centrate characteristics:	
CBOD (mg/l)	_____
Flow (gpd)	_____

wq-wwtp5-13



